



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx SIR 13.0069X

Issue No: 5

Certificate history:

Issue No. 5 (2019-06-11)

Issue No. 4 (2017-07-11)

Issue No. 3 (2016-08-30)

Issue No. 2 (2016-04-18)

Issue No. 1 (2014-12-01)

Issue No. 0 (2013-04-19)

Status: **Current**

Page 1 of 4

Date of Issue: **2019-06-11**

Applicant: **Rosemount Inc.**
8200 Market Boulevard
Chanhassen
Minnesota 55317
United States of America

Equipment: **Spectrex - Open Path Gas Detector and SafEye Quasar 900/950/960**

Optional accessory:

Type of Protection: **Flameproof, Increased Safety, Intrinsic Safety and Dust Protection by Enclosure**

Marking:

Ex db eb ib [ib Gb] IIB + H₂ T4 Gb
Ex tb III C T135°C Db
Ta = -55°C to +65°C

Approved for issue on behalf of the IECEx
Certification Body:

R A Craig

Position:

Certification Support Officer

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

SIRA Certification Service
CSA Group
Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
United Kingdom

sira
CERTIFICATION





IECEx Certificate of Conformity

Certificate No: IECEx SIR 13.0069X

Issue No: 5

Date of Issue: 2019-06-11

Page 2 of 4

Manufacturer: **Rosemount Inc.**
6021 Innovation Boulevard,
Shakopee
Minnesota 55379-9795
United States of America

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2014-06 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-28 : 2015 Edition:2	Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2015 Edition:5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/SIR/ExTR13.0101/00](#)

[GB/SIR/ExTR14.0127/00](#)

[GB/SIR/ExTR16.0083/00](#)

[GB/SIR/ExTR16.0221/00](#)

[GB/SIR/ExTR17.0103/00](#)

[GB/SIR/ExTR19.0162/00](#)

Quality Assessment Report:

[GB/BAS/QAR06.0072/08](#)



IECEx Certificate of Conformity

Certificate No: IECEx SIR 13.0069X

Issue No: 5

Date of Issue: 2019-06-11

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Refer to the Annexe for the description and Conditions of Manufacture

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to the Annexe



IECEx Certificate of Conformity

Certificate No: IECEx SIR 13.0069X

Issue No: 5

Date of Issue: 2019-06-11

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

This issue, Issue 5, recognises the following change; refer to the certificate annex to view a comprehensive history:

1. The recognition of minor modification updated to label drawings i.e. the alteration of the ATEX notified body number, which does not impact the IECEx certification scheme.

Annex:

[IECEx SIR 13.0069X Annexe Issue 5.pdf](#)

Annexe to: IECEx SIR 13.0069X Issue 5
Applicant: Rosemount Inc.
Apparatus: Spectrex - Open Path Gas Detector
SafEye Quasar 900



The SafEye Quasar 900 Series Open Path Gas Detector, consists of four source units and one type of detector with electrical ratings as follows:

Type	Model No.	Voltage Supply Range	Peak Supply Current
Detector	QR-C-11X	18 - 32 Vdc	200 mA
Source 1	QT-C-11X	18 - 32 Vdc	220 mA
Source 2	QT-C-21X	18 - 32 Vdc	220 mA
Source 3	QT-C-31X	18 - 32 Vdc	220 mA
Source 4	QT-C-41X	18 - 32 Vdc	260 mA

The Quasar 900 Series includes four models each using the same detector with a different source to provide the ability to detect at distances of 7 - 200m.



The enclosure used for both the source and detector units of, is of cylindrical construction, made of stainless steel and has two separate chambers; one flameproof and one increased safety. The equipment is shown below in a typical mounting arrangement.

At one end of the flameproof chamber there is an end cap secured with four screws forming a spigot joint with the main enclosure. This end cap has a sapphire window in the centre which is secured from the inside with a retaining ring screwed to the enclosure; this window forms a flanged joint against the enclosure. Externally, there is a hood above the sapphire window and a permanent guard.

There is a spigot joint at the opposite end of the flameproof enclosure, formed by another end cap, with identical flamepath dimensions as those at the sapphire window end. The other side of this end cap forms part of the increased safety chamber. The two spigot joints are each secured by four M6 x 1.0 stainless steel socket head cap screws which have a minimum yield stress of 344 N/mm².

The base of the increased safety enclosure protrudes from the flameproof enclosure end cap, has two ¾" NPT or M25 threaded entries on one side and a 3 5/8" parallel thread on the end, to which a threaded cover is attached. This threaded cover has a glass window secured from the inside by a threaded retaining ring.

The flameproof and increased safety chambers are separated by a partition with a cylindrical section filled with a non-metallic compound forming a bushing, through which there are cables for the connection of circuits between the two chambers.

Inside the flameproof chamber there are a range of PCBs, including some I.S. barriers. The outputs of these I.S. barriers are fed to an LED situated in the increased safety enclosure and on the detector units, to the I.S. port mounted on the side of the enclosure. There are also some component approved increased safety terminals inside the increased safety enclosure for connection to circuits in the flameproof enclosure and to external circuits.

The area behind the I.S. connector port is filled with non-metallic compound and forms a cemented joint. The outputs from the I.S. port are fed from the I.S. barriers and are therefore intrinsically safe.

All joints on which dust protection by enclosure depends are fitted with ethylene propylene O-rings.

The gas detectors meet level of protection IP6X and have been independently tested according to the requirements of IEC/EN 60529 to meet IPX6.

Sira Certification Service

Unit 6 Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: ukinfo@csagroup.org
Web: www.csagroupuk.org

Annexe to: IECEx SIR 13.0069X Issue 5

Applicant: Rosemount Inc.

Apparatus: Spectrex - Open Path Gas Detector
SafEye Quasar 900



The interface board located in the equipment provides intrinsically safe outputs. The maximum voltage that can be applied to the interface board is $U_m=32V$.

Intrinsically safe outputs have the following parameters:-

Parameter		Channel						
		LED 1	LED 2	HART CON	RS485 +	RS485 -	5V	All combined
Uo	=	6.51V	6.51V	6.51V	6.51V	6.51V	6.51V	6.51V
Io	=	68.5mA	68.5mA	68.5mA	68.5mA	68.5mA	263mA	605.5mA
Po	=	111.5mW	111.5mW	111.5mW	111.5mW	111.5mW	428mW	0.986W
Ci	=	0μF	0μF	0μF	0μF	0μF	0μF	0μF
Li	=	0μH	0μH	0μH	0μH	0μH	0μH	0μH

These outputs connect to circuits external to the Ex d enclosure.

- The dimensions of the flameproof joints are other than the relevant minimum or maximum values required by table 2 of IEC 60079-1:2007/EN 60079-1:2007 for IIB + H₂, as detailed below

Flamepath Description	Type of joint	Minimum Width 'L' (mm)	Maximum Gap iC (mm)
Cylindrical section of spigot (both ends of Ex d compartment)	Cylindrical	15	0.08
30 mm diameter window fitted against enclosure	Flanged	10.7	0.02
39.5 mm diameter window fitted against enclosure	Flanged	10	0.02

Gaps shall not be machined to be any larger than the values of 'iC', and widths shall not be modified to be any smaller than the values of 'L', shown in the table above

- Connections to the I.S. port on the side of the detector enclosure shall be made via equipment which maintains the intrinsically safe levels of protection.
- Where U_m marked on the associated apparatus is less than 250V it shall be installed in accordance with one of the following:

Conditions Of Manufacture

- Each unit shall be subjected to a dielectric strength test in accordance with IEC 60079-7:2006 clause 6.1 for at least 1 second. Alternatively, 1.2 x the test voltage may be applied and maintained for at least 100 ms.
- The window section of each enclosure shall be subjected to a routine overpressure test at 31 bar for at least 10 s as required by clause 16.1 of IEC 60079-1:2007. There shall be no damage to the window.
- The manufacturer shall provide the user/installer with an appropriate copy of the certificate for each component approved device that is fitted in the equipment.
- The end user shall not have the option to change the settings of the software such that there will be an increase in power dissipation/current consumption beyond that of the models listed on the certificate.

Annexe to: IECEx SIR 13.0069X Issue 5
Applicant: Rosemount Inc.
Apparatus: Spectrex - Open Path Gas Detector
SafEye Quasar 900



Issue 1 – this Issue introduced the following changes:

1. The thickness of the sapphire window which is installed in the end cap was increased from 3 mm to 4 mm.
2. Options to include a sun shade P/N 888263 and tilt mount P/N 888270 were introduced.
3. The inclusion of new drawings showing the sunshade and tilt mechanism assemblies
4. Minor drawing modifications including: inclusion of label dimensions, TUV logo added inclusion of new notes for clarification, change of ground symbols.
5. The entry hole for external wiring was enlarged.
6. Re-assessment of safety component ratings in a higher internal ambient temperature

Issue 2 – this Issue introduced the following change:

- 1 Component description updates to capture previous typographical errors and to note previously Minor drawing modifications were recognised, these modifications include the correction of typographical errors, note that some component parts have been externally assessed for RoHS compliance and introduce clarifying notes.

Issue 3 – this Issue introduced the following changes:

1. The introduction of two new open path gas detectors for toxic gasses such as ammonia, H₂S etc., models 950/960. These models include two detectors QRU-C-11X/QRU-C-21X and three sources QTU-C-11X/QTU-C-21X/QTU-C-31X. The sources incorporate a new, component approved, optical source that is covered by ExTR no. DE/PTB/ExTR16.0012/00.

Type	Model No.	Voltage Range	Supply	Peak Supply Current
Detector	QRU-C-11X	18 - 32 Vdc		200 mA
Detector	QRU-C-21X	18 - 32 Vdc		200 mA
Source	QTU-C-11X	18 - 32 Vdc		220 mA
Source	QTU-C-21X	18 - 32 Vdc		220 mA
Source	QTU-C-31X	18 - 32 Vdc		220 mA

2. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, IEC 60079-1:2007 Ed 6, IEC 60079-7:2006 Ed.4 and IEC 60079-31:2008 Ed 1 were replaced by IEC 60079-1:2014 Ed 7, IEC 60079-7:2015 Ed.5, IEC 60079-28:2015 Ed.2 and IEC 60079-31:2013 Ed 2, the markings were updated accordingly.

Issue 4 – this Issue introduced the following change:

1. The transfer of Ownership:

From	To
Spectrex Limited 218 Little Falls Road Cedar Grove New Jersey 07009 USA	Rosemount Inc. 8200 Market Boulevard Chanhassen Minnesota 55317 United States of America

Issue 5 – this Issue introduced the following change:

- 1 The recognition of minor modification updated to label drawings i.e. the alteration of the ATEX notified body number, which does not impact the IECEx certification scheme.

Sira Certification Service

Unit 6 Hawarden Industrial Park,
Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: ukinfo@csagroup.org
Web: www.csagroupuk.org